

BLOCK PACKADGE MONO AND SPLIT COOLING UNITS COMPAIRING TABLE



NO	SPECIALTY TYPE	11	16	25	30	45	50	60	70	80	90	100	PROF	ECO	CLASS			
1	Compressor Type	9513	4519	4531	4540	4553	4561	4568	4573	5590	5610	5612	*	*	*			
2	Compressor Capacity-HP	1,1	1,6	2,5	3,0	4,5	5,0	6,0	7,0	8,0	9,0	10,0	*	*	*			
3	Compressor Capacity- kW	1,97	3,13	4,76	5,85	7,22	8,34	9,47	10,2	12,58	13,5	16,56	*	*	*			
4	Condenser- m2	12	16	25	30	40	50	63	63	73	81	105	*	*	*			
5	Cooler, K.Watt	2,79	3,7	5,8	6,9	9,3	11,6	14,6	14,6	16,9	18,8	24,4	*	*	*			
6	Fan-piece x f	2x30	2x30	2x35		2 x 45						3x45	*	*	*			
7	Vibration Remover- Suction	5/8		7/8			1 1/8				1 3/8	*						
8	Vibration Remover- Push	3/8		1/2		5/8			7/8				*					
9	Liquid Bin	3/8			1/2			5/8						*	*			
10	Chassis+ sheet + Paint, m2	5	5	6,5	7,5	8,5	7,5	9	9	10	10,5	13	*	*	*			
11	Solenoid Valve- Gas	1/4		3/8			1/2						*	*				
12	Solenoid Valve- Defrost	3/8		1/2		5/8						*	*					
13	LP/HP Presostate-Without Reset	1/4											*	*	*			
14	YBL Presostate – Without reset	1/4											*					
15	Oil separator	1/2			5/8			7/8						*				
16	Liquid holder	7/8					1 1/8						*					
17	Expansion Valve/ALCO HW	1		2		3		4		5		6		6		*	*	*
18	Drayer /ALCO	1/4	3/8					1/2				*	*	*				
19	Observation glass	1/4	3/8					1/2				*		*				
20	Defrost Valve	3/8		1/2		5/8			7/8						*			
21	Storage Valve	3/8		1/2		5/8						*	*					
22	F 22 Gas kg.	4	5	6	7	9	10	11	12	13	14	15	*	*	*			
23	Digital Unit T60S	STANDART											*	*	*			
24	W-Automat Fuse 3 x...A	3x10			3x16		3x25			3x32		3x42		*	*	*		
25	Observation Bulb 220 V	STANDART											*	*	*			
26	Pako Breaker 1-0-2 Standart	STANDART											*	*	*			
27	Contactör /SIEMENS 3TF	3 TF42					3 TF62						*	*	*			
28	Termic 3 x.....Amp.	3x7	3x4	3x6	3x7	3x10	3x12	3x12	3x15	3x15	3x20	3x20	*	*	*			